



**PUBLIC SAFETY**  
**TOWN OF HAMLIN**

1658 LAKE ROAD  
P.O. BOX 148  
HAMLIN, NEW YORK 14464-0148

Phone (585) 964-8181  
Fax (585) 964-9124  
TDD# 1-800-662-1220

Fire Marshal   
Code Enforcement

# Permit Application

## For Tent/Canopy

Applicant: \_\_\_\_\_

Location: \_\_\_\_\_

Date(s): \_\_\_\_\_

### Rules Governing the Issuance of Permit

- Maximum length of use 180 days within a 12 month period
- Construction Documents. Details of:
  - Site and floor plan if occupant load is 50 or more
  - Means of egress per chart 2403.12.2 NYS Fire Code
  - Seating capacity
  - Arrangement of seating
  - Location and type of heating and electrical equipment
- Inspection to be made by the Fire Marshal after erected and before use
- Location- 20' up to 15,000 sq. ft. and 50' if over 15,000 sq. ft. from lot lines, buildings, other tents, parked vehicles or internal combustion engines.
- Fire Lane-unobstructed 12' wide to tent and all around tent.
- Required 44" isle width and not less than 1' per 50 people served by isle
- No smoking is allowed and no smoking signs shall be posted
- Fire extinguishers per table 906.3 NYS Fire Code

Applicant Signature \_\_\_\_\_ Date \_\_\_\_\_

Fire Marshal Signature \_\_\_\_\_ Date \_\_\_\_\_